

Cliffside Park Public Schools

**Corrective Action Plan
Drinking Water**

School #3

None

Corrective Action to be Taken

None

School #4

2nd floor classroom 207 sink 17.6 ug/l

Eliminate Sink

School #5

2nd floor bathroom sink near staircase 34.8 ug/l

Replace Values/faucets.

1st floor classroom 107 sink 150 ug/l

Eliminate Sink.

1st floor nurse's bathroom sink 111ug/l

Replace Values/faucets.

1st floor main office water fountain 16.2 ug/l

Replace fountain

Cliffside Park HS:

1st floor sink Classroom 122 39.9 ug/l

Replace Values/faucets.

1st floor sink classroom 123 34.5 ug/l

Replace Values/faucets.

1st floor sink classroom 125 26.4 ug/l

Replace Values/faucets.

1st floor faculty bathroom sink 18.4 ug/l

Replace Values/faucets.

1st floor faculty bathroom sink/computer room 16.3 ug/l

Replace Values/faucets.

School #6:

Basement water fountain 58.3 ug/l

Eliminate fountain.

Classroom 116 water fountain 34.0 ug/l

Eliminate fountain.